SCD Configured for Low Voltage area of Integrated Application Testing - Kalkitech SCL Manager							
Si N	**Area in LV**	**Used as**	**Make**	**IED Name**	**ICD/CID/IID File Name**	**IP Address**	**SV / GOOSE Multicast**
1	Incomer A	Bay Controller	GE	GE_C264_INC_A_BC	GE_C264_BayController_ED2.icd	10.14.18.1	01-0C-CD-01-18-31
2		Merging Unit	Siemens	SIE_6MU805_INC_A_MU01	6MU805 HV Line.icd	10.14.35.1	01-0C-CD-04-35-31
3		Protection IED	GE / Siemens	(Will be configured in HV SCT)	GE_P645_Transformer_ED2.ICD / Siprotec_7UT87.icd		
4	Incomer B	Bay Controller	Kalkitech	Kalkitech_Sync3K_INC_B_BC	Sync3k_BCU.icd	10.14.20.11	01-0C-CD-01-20-31
5		Recorder	Novatech	Novatech_BT_M871_INC_B_Mtr	bitronics_M871_0000000000000000	10.14.25.1	
6		Protection IED	GE / ERLPhase	(Will be configured in HV SCT)	GE_T60_Line2_IED.iid / ERLPhaseTPRO4000v3.icd		
7	A1	Bay Controller	Kalkitech	Kalkitech_Sync3K_A1_BC	Sync3k_BCU.icd	10.14.20.21	01-0C-CD-01-20-3A
8		Merging Unit	Siemens	SIE_6MU805_A1_MU02	6MU805 HV Line.icd	10.14.35.2	01-0C-CD-04-35-32
9		Protection IED	CYG	CYG_PR7367_A1_P1_IED	CYG_PRS7367_Ed2.icd	10.14.15.1	01-0C-CD-01-15-31
10	A2	Bay Controller	RTDS	RTDS_GNT_A2_BC	RTDS_GNT_20170914.icd	10.14.32.1	01-0C-CD-01-32-31
11		Merging Unit	RTDS	RTDS_SV_A2_MU	RTDS_SV_1_2.cid	10.14.32.2	01-0C-CD-04-32-31
12		Protection IED	NRR	NRR_PCS9611_A2_IED	NR_PCS9611_Ed2.icd	10.14.26.1	01-0C-CD-01-26-31
13	A3	Bay Controller	Omicron	Omicron_ISIO200_XF_BC		10.14.27.1	01-0C-CD-01-27-31
14		Merging Unit					
15		Protection IED					
	Bus Transfer						
16	Bus Tie Breaker	Bay Controller	CYG	CYG_PRS7395_B1_MU_BC	CYG_PRS7395.icd	10.14.15.11	01-0C-CD-01-15-3A
17		Merging Unit	CYG	CYG_PRS7395_B1_MU_BC	CYG_PRS7395.icd	10.14.15.11	01-0C-CD-04-15-3A
18		Protection IED	SEL	SEL_751_B1_P1_IED	SEL-751-Ed2.ICD	10.14.34.1	01-0C-CD-01-34-31
19	B1	Bay Controller					
20		Merging Unit	Vizimax	Vizimax_MGU0100000_BTB_MU	MGU010000_v1.3_beta_SCL_Ed2.icd	10.14.39.2	01-0C-CD-04-39-31
21		Protection IED					
	B2						
22		Client	Kalkitech - ASE	ASE61850Client	ASE61850Client.icd	10.14.20.1	
22		Client	COPA DATA	zenon_iec850Client2	COPADATA_zenonIEC850Client2_Ed2	10.14.14.1	